

DISTRICT WATER TESTING LABORATORY PHED Division VIDISHA
Near Ramlila Maidan Drainage colony Mandi road Vidisha -464001

Test Report

Desp. No.99



Date 28.07.2025

Report No 99 Date 28.07.25

A Name and address

Principal, VIDYA International School,
Genhukhedi, Vidisha

2. Particulars of a sample place of collection & Details

B Reference No.

Nil

3 Date and Time of sample receive

28.07.25

4 Date of analysis start

28.07.25

3 Date of analysis end

28.07.25

4 Unique ID

1920

5 Condition of the sample Ok/Not Ok

OK

1920	Vidisha-Genhukhedi- Vidya International School Campus

S.No.	Name of parameter	Name of test methods used	BIS 10500:2012 Reaffirmed in Sep. 2018		Unit	Unique ID				
			desireble limits	Permissible limits		1920				
1	Tempraturtre	Celsius			Degree C	25C				
2	Turbidity	part 10	1	5	NTU	1.00				
3	Colour	part 04	5	15	Hazon Scale	Nil				
	Taste	Part 7, 8	Agreeable	Not Agreeabl	None	Agreeable				
4	Odour	part 05	Agreeable	Not Agreeabl	None	Agreeable				
5	pH	Part 11	6.5 -8.5	No relax.	pH Scale	7.24				
6	Conductivity	Part 16			Micromho/cm	388				
7	Total solids	Part 16	500	2000	Mg/L	229				
8	Total Alkalinity	Part 23	200	600	Mg/L	98				
9	Total Hardness as Caco3	Part 21	200	600	Mg/L	205				
10	Ca as Ca++	Part 40	75	200	Mg/L	52				
11	Mg as Mg++	Part 46	30	100	Mg/L	18				
12	Chloride	Part 32	250	1000	Mg/L	134				
13	Nitrate as No3	Part 34	45	45	Mg/L	3.00				
14	Iron	Part 53	0.3	1.00	Mg/L	0.21				
15	Fluoride	Part 60	1	1.5	Mg/L	0.26				
16	Sulfate	Part 24	200	400	Mg/L	3.00				
17	Magnese	Part 59	0.1	0.3	Mg/L	Nil				
18	Arsenic	Part 37	0.01	0.05	Mg/L	Nil				
19	Faecal coliform	Part 19	0/100	0/100	per 100 ml	0.00				
20	Total coliform	Part 19	0/100	0/100	Per 100 ml	0.00				

Note 1 Sample has been provided by the customer and Sample tested as received

2 The result applied to sample as received

3 Report shall not be reproduce except in full without approval of the laboratory.

4. Sample will be retained for 15 days.

Signature of analyst

District water testing laboratory Vidisha (M.P.)

Sanjay Dubey

Authorised Signatory & Quality manager
District Water testing laboratory Vidisha (M.P.)

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENo. 99Date : 30.07.2025

It is certified that an inspection team headed by Sanjay Dubey
Quality Manager & chemist Pheorge lab from District
Water testing lab

PHED inspected the Vidya International School,
 Bhopal – Sagar Bypass Gehukhedi on 28.07.2025 and on the basis of Water Test
 Report (Attached) bearing no. 99 dated 30.07.2025 of
District water testing lab (PHED Lab) certified that the Vidya
 International School has safe drinking water facilities for the students and members of staff
 of the institution. School also maintains the hygienic sanitation condition in the school
 building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above certificate is valid for a period of one year.

Signature with Stamp

Name :

Sanjay Dubey

Designation :

Name & Address of the Office/ Department:

Quality Manager
4 chemist District water testing
Lab PHED, Vidisha

To

Vidya International School

Bhopal - Sagar bypass

Gehukhedi Dist. Vidisha (M.P)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies